

VOC Content Test Certificate

Friday April 17th, 2009

Supplier: Polyflor Australia (59 – 65 Wedgewood Road, Hallam Victoria 3803)

Sample Description: Kiesel Star100 flooring adhesive

Date Tested: April 2009

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification	
Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	Kiesel Star100
Flooring Adhesive 50 grams per Litre as VOC content material	25 grams per Litre as VOC content per coating
Specification	
Green Building Council of Australia Green Star Office Design V3 IEQ-13	Kiesel Star100
Flooring Adhesive 50 grams per Litre as VOC content material	25 grams per Litre as VOC content per coating



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0904-12