

# VOC Content Test Certificate

Wednesday 4<sup>th</sup> August 2010

Manufacturer: PolyFlor Pty Ltd (59-65 Wedgewood Rd, Hallam, VIC, 3803)

Sample Description: Kiesel Servoplan S444 Self Leveling Compound

Date Tested: July 2010 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<b>Specification</b>	
<b>Green Building Council of Australia Green Star Office Design V2 IEQ-13</b>	<b>Kiesel Servoplan S444 Self Leveling Compound</b>
Architectural Sealant 250 grams per Litre as VOC content material	<b>12 grams per Litre as VOC content material</b>
<b>Specification</b>	
<b>Green Building Council of Australia Green Star Office Design V3 IEQ-13</b>	<b>Kiesel Servoplan S444 Self Leveling Compound</b>
Architectural Sealant 250 grams per Litre as VOC content material	<b>12 grams per Litre as VOC content material</b>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

F1007-16