

# VOC Content Test Certificate

Monday January 5<sup>th</sup>, 2009

Supplier: Sika Australia Pty Ltd (55 Elizabeth Street, Wetherill Park NSW 2164)

Sample Description: Sika Boom FR fire rated expanding polyurethane foam

Date Tested: January 2009

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Office Design V2 IEQ-13</b> <b>Green Star Office Interiors V1.1 IEQ-11</b>	<b>Sika Boom FR</b>
Architectural sealant 250 grams per Litre as VOC content coating	<b>&lt;10 grams per Litre as VOC content per coating</b>
<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Office Design V3 IEQ-13</b>	<b>Sika Boom FR</b>
Architectural sealant 250 grams per Litre as VOC content coating	<b>&lt;10 grams per Litre as VOC content per coating</b>



Dr. Vyt Garnys  
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
 ACA, AIRAH, FMA  
 Managing Director and Principal Consultant

F0812-37