

Exova Warringtonfire
Holmesfield Road
Warrington
WA1 2DS
United Kingdom

T : +44 (0) 1925 655 116
F : +44 (0) 1925 655 419
E : warrington@exova.com
W: www.exova.com



Testing. Advising. Assuring.

Title:

CLASSIFICATION OF
REACTION TO FIRE
PERFORMANCE
IN ACCORDANCE WITH
EN 13501-1: 2007

Notified Body No:

0833

Product Name:

Polyflor Standard XL /
Robust XL / Voyager XL, 1.5-
2mm

Report No:

192851

Issue No:

1

Prepared for:

Polyflor Limited, PO Box 3,
Radcliffe New Road,
Whitefield, Manchester,
M25 7NR

Date:

28th May 2010

1. Introduction

This classification report defines the classification assigned to “Polyflor Standard XL / Robust XL / Voyager XL”, a homogenous PVC flooring, in accordance with the procedures given in EN 13501-1:2007

2. Details of classified product

2.1 General

The product, “Polyflor Standard XL / Robust XL / Voyager XL”, a homogenous PVC flooring is defined as being suitable for floorcovering applications.

2.2 Product description

The product, “Polyflor Standard XL / Robust XL / Voyager XL”, a homogenous PVC flooring, is fully described below and in the test reports provided in support of classification listed in Clause 3.1.

General description		Homogenous flooring, adhered to a 6mm thick fibre cement board substrate utilising ‘F44’ adhesive
Floor Covering	Product reference	Polyflor Standard XL / Robust XL / Voyager XL
	Generic type	Polyvinyl Chloride (PVC)
	Weight per unit area	1.5 mm = 2.36 kg/m ² 2.0 mm = 3.20 kg/m ²
	Thickness	1.5 – 2.0 mm
	Colour	Any
	Shade	Any
	Flame retardant details	The sponsor stated that no flame retardant additives were utilised in the manufacture of the floorcovering
Adhesive	Product reference	“Styccobond F44”
	Generic type	Acrylic based adhesive
	Name of manufacturer	F Ball & Co. Ltd.
	Application rate	200 g/m ²
	Application method	‘V’ notched trowel
	Flame retardant details	The manufacturer stated that no flame retardant additives were utilised in the construction of the adhesive
Substrate	Trade name	“NT D4 604”
	Generic type	Fibre cement board
	Thickness	6mm
	Density	1800kg/m ³
Brief description of manufacturing process of the floor covering		Calendered flooring

Note: The precise composition of the product submitted for test is regarded by the sponsor to be of a highly confidential nature and as a consequence this information is maintained by Polyflor at their Whitefield factory. This information can be inspected by Exova warringtonfire at anytime and the information is checked, stamped, signed and dated by a member of Exova warringtonfire to prevent misuse.

3. Test reports/extended application reports & test results in support of classification.

3.1 Test reports/extended application reports.

Name of Laboratory	Name of sponsor	Test reports/extended application report Nos.	Test method / extended application rules & date
BCTC	Polyflor Limited	26/00486/04/07 26/00489/04/07	EN ISO 11925-2
BCTC	Polyflor Limited	26/00486/04/07 26/00489/04/07	EN ISO 9239-1
Exova warringtonfire	Polyflor Limited	WF192854	EN/TS 15117

3.2 Test results

Test method & test number		Parameter	No. tests	Results	
				Continuous parameter - mean (m)	Compliance with parameters
EN ISO 9239-1		Critical flux	3	>11.0, >11.0, >11.0	Compliant
		Smoke		22, 20, 31, 9, 23, 15	Compliant
EN ISO 11925-2	(15s exposure – surface warp)	F _s	6	None	Compliant
		Flaming droplets/ particles		None	Compliant
	(15s exposure – surface weft)	F _s	6	None	Compliant
		Flaming droplets/ particles		None	Compliant

4. Classification and field of application

4.1 Reference of classification

This classification has been carried out in accordance with clause 9 of EN 13501-1:2007

4.2 Classification

The product, "Polyflor Standard XL / Robust XL / Voyager XL", a homogenous PVC flooring, in relation to its reaction to fire behaviour is classified:

B_{FL}

The additional classification in relation to smoke production is:

s1

The format of the reaction to fire classification for floorings is:

Fire Behaviour		Smoke Production	
B_{FL}	-	s	1

i.e. **B_{FL} – s1**

Reaction to fire classification: B_{FL} – s1

4.3 Field of application

This classification is valid for the following end use applications:

- i) Floorcovering applications bonded directly to any substrate with a minimum density of 1800kg/m³, having a minimum thickness of 6mm and a fire performance of A2_{FL} or better.
- ii) Installed directly to the substrate utilising 'F44' adhesive, applied at a nominal rate of 200g/m²

This classification is also valid for the following product parameters:

Floorcovering thickness	1.5 to 2mm
Floorcovering weight per unit area	2.36 to 3.20 kg/m ²
Floorcovering composition	No variation allowed
Colour/Pattern	Any variation allowed
Adhesive	No variation allowed
Adhesive application rate	No variation allowed
Adhesive application method	No variation allowed

SIGNED




.....

Matthew Dale

Certification Engineer
Technical Department

APPROVED



.....

Janet Murrell

Technical Manager
Technical Department
on behalf of **Exova warringtonfire**

This copy has been produced from a .pdf format electronic file that has been provided by Exova Warringtonfire to the sponsor of the report and must only be reproduced in full. Extracts or abridgements of reports must not be published without permission of Exova Warringtonfire. The original signed paper version of this report is the sole authentic version. Only original paper versions of this report bear authentic signatures of the responsible Exova Warringtonfire staff.