

VOC Content Test Certificate

Thursday April 16th, 2009

Supplier: Polyflor Australia (59 – 65 Wedgewood Road, Hallam Victoria 3803)

Sample Description: Kiesel Polyurethane rubber flooring adhesive

Date Tested: April 2009

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11	Kiesel Polyurethane
Rubber Flooring Adhesive 60 grams per Litre as VOC content material	<10 grams per Litre as VOC content per coating
Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	Kiesel Polyurethane
Rubber Flooring Adhesive 60 grams per Litre as VOC content material	<10 grams per Litre as VOC content per coating



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F0904-12