

Emission Test Certificate

Monday 23rd September 2024

Supplier Armstrong Flooring (GATE 2, 29-39 MILLS ROAD, BRAESIDE, VIC, 3195, Australia).

Product Name Armstrong Flooring Homogeneous Sheet Vinyl Products

Date Tested July 2024 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (28 days):

Green Building Council of Australia Green Star Design & As Built V1.3 - 13.1.2B & 13.2 Green Star Interiors V1.3 - 12.2	Armstrong Flooring Homogeneous Sheet Vinyl Products
Total Volatile Organic Compound Emission Rate Limit: $\leq 0.500 \text{ mg/m}^2/\text{hr}$	Total Volatile Organic Compound Emission Rate: $0.060 \text{ mg/m}^2/\text{hr}$
4-phenylcyclohexene Emission Rate Limit: $< 0.05 \text{ mg/m}^2/\text{hr}$	4-phenylcyclohexene Emission Rate: $< 0.001 \text{ mg/m}^2/\text{hr}$
Formaldehyde Emission Rate Limit: $\leq 0.100 \text{ mg/m}^2/\text{hr}$	Formaldehyde Emission rate: $< 0.005 \text{ mg/m}^2/\text{hr}$
<i>The results above may be considered representative of the equivalent and lesser weighted product specifications that are made from the same raw material by Armstrong Flooring and these include Accolade Plus; Accolade Safe; Accolade Foothold; Natralis; Natralis Foothold; Australis; Quantum; Infinity; Infinity Safe; and Infinity Foothold.</i>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant



Dr. Tuan Duong
PhD, B.Eng. (Chemical)
Senior Consultant