

Emission Test Certificate

Wednesday 17th January 2024

Supplier	Armstrong Flooring (GATE 2, 29-39 MILLS ROAD, BRAESIDE, VIC, 3195, Australia).
Product Name	Armstrong Flooring Luxury Vinyl 2.0 - 5.0mm
Date Tested	January 2024 (Tested by FORAY Laboratories – NATA Accreditation 1231)
Test Method	ASTM D5116-2017 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (24 hrs):

Green Building Council of Australia Green Star Design & As Built V1.3 - 13.1.2B & 13.2 Green Star Interiors V1.3 - 12.2	Armstrong Flooring Luxury Vinyl 2.0 - 5.0mm
Total Volatile Organic Compound Emission Rate Limit: $\leq 0.500 \text{ mg/m}^2/\text{hr}$	Total Volatile Organic Compound Emission Rate: $0.069 \text{ mg/m}^2/\text{hr}$
Formaldehyde Emission Rate Limit: $\leq 0.100 \text{ mg/m}^2/\text{hr}$	Formaldehyde Emission rate: $0.011 \text{ mg/m}^2/\text{hr}$



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Travis Hale
BSc (Biotechnology)
Senior Consultant



Dr. Tuan Duong
PhD, B.Eng. (Chemical)
Senior Consultant