

# VOC Content Test Certificate

Friday April 17<sup>th</sup>, 2009

Supplier: Polyflor Australia (59 – 65 Wedgewood Road, Hallam Victoria 3803)

Sample Description: Kiesel EG20 primer for the preparation of non- absorbent and absorbent substrates.

Date Tested: April 2009

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Office Design V2 IEQ-13</b> <b>Green Star Office Interiors V1.1 IEQ-11</b>	<b>Kiesel EG20</b>
Architectural Sealant 250 grams per Litre as VOC content material	<b>&lt;10 grams per Litre as VOC content per coating</b>
<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Office Design V3 IEQ-13</b>	<b>Kiesel EG20</b>
Architectural Sealant 250 grams per Litre as VOC content material	<b>&lt;10 grams per Litre as VOC content per coating</b>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

F0904-12