

VOC Content Test Certificate

Wednesday August 22nd, 2012

Manufacturer: Polyflor Australia (59-65 Wedgewood Rd, Hallam VIC 3803)

Sample Description: STAR 110

Date Tested: August 2012 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 303-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

Specification Green Building Council of Australia Green Star Office Design V3 IEQ-13	STAR 110
Rubber flooring adhesive 60 grams per Litre as VOC content per material	11 grams per Litre as VOC content per material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Anne Saletti
BNanotech/BSc(Hons)
Consultant

CV120811