

VOC Content Test Certificate

Tuesday 25th October 2022

Supplier Ardex Australia Pty Ltd (Unit 7, 20 Powers Road, SEVEN HILLS, NSW 2147, Australia).

Sample Description Ardex A48 22H007N

Date Tested October 2022 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method ASTM D3960 & ASTM D2369 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred to in accordance with the laboratory testing guidance from the Green Building Council of Australia.

Test Results

| | |
|--|---|
| Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B | Ardex A48 22H007N |
| General Purpose Adhesives and Sealants Limit: 50 grams per litre | 1 gram per litre as VOC content per material |
| Meets GBCA VOC Content Requirement | Yes |



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant



Dr. Tuan Duong
 PhD, BE (Chem. Eng.)
 Senior Consultant



Travis Hale
 BSc (Biotechnology)
 Senior Consultant

P22090047