

Fire-resistance test on sealing systems protecting control joints in concrete walls

Test Report

Author: Chris Wojcik

Report number: FSP 1819

Date: 3 April 2017

Client: Sika Australia Pty Ltd

Commercial-in-confidence




Inquiries should be address to:

| | | |
|------------------------------|-----------------------------|---------------------------|
| Fire Testing and Assessments | Author | The Client |
| NATA Registered Laboratory | Infrastructure Technologies | Sika Australia Pty Ltd |
| 14 Julius Avenue | 14 Julius Avenue | 55 Elizabeth Street |
| North Ryde, NSW 2113 | North Ryde, NSW 2113 | Wetherill Park NSW |
| Telephone +61 2 9490 5444 | Telephone +61 2 9490 5500 | Telephone +61 2 9757 5665 |

Report Status and Revision History:

| VERSION | STATUS | DATE | DISTRIBUTION | ISSUE NUMBER |
|------------|--------------------------------|------------|--------------|--------------|
| Revision A | Draft for internal review | 19/03/2017 | CSIRO/CLIENT | FSP 1819 |
| Revision B | Final for issue | 25/03/2017 | CLIENT | FSP 1819 |
| Revision C | Amend drawings/Final for issue | 03/04/2017 | CLIENT | FSP 1819 |

Report Authorization:

| AUTHOR | REVIEWED BY | AUTHORISED BY |
|---|---|---|
| Chris Wojcik | Brett Roddy | Brett Roddy |
|  |  |  |
| 3 April 2017 | 3 April 2017 | 3 April 2017 |

Use of this Report

Use of Reports – Testing

This report is subject to binding obligations under which it was prepared. In particular, the Report must not be used:

- *as a means of endorsement; or*
- *in a company prospectus or notification to a Stock Exchange document for capital raising, without the prior written consent of CSIRO.*

The Report may be published verbatim and in full, provided that a statement is included on the publication that it is a copy of the Report issued by CSIRO.

Excerpts of the Report may not be published.

Use of Reports – Consultancy

This report is subject to binding obligations under which it was prepared. In particular, the Report may only be used for the following purposes:

- *the information in the Report may be used by the party that commissioned the Report for its internal business operations (but not licensing to third parties);*
- *the report may be copied for distribution within the organisation that commissioned the Report;*
- *copies of the Report (or extracts of the Report) may be distributed to contractors and agents of the organisation that commissioned the Report who have a need for the Report for its internal business operations. Any extracts of the Report distributed for this purpose must clearly note that the extract is part of a larger Report held by the organisation that commissioned the Report and which has been prepared by CSIRO.*

The name, trade mark or logo of the CSIRO must not be used without the prior written consent of CSIRO.

The Report must not be used as a means of endorsement without the prior written consent of CSIRO.

Copyright and disclaimer

© 2017 CSIRO To the extent permitted by law, all rights are reserved and no part of this publication covered by copyright may be reproduced or copied in any form or by any means except with the written permission of CSIRO.

Important disclaimer

CSIRO advises that the information contained in this publication comprises general statements based on scientific research. The reader is advised and needs to be aware that such information may be incomplete or unable to be used in any specific situation. No reliance or actions must therefore be made on that information without seeking prior expert professional, scientific and technical advice. To the extent permitted by law, CSIRO (including its employees and consultants) excludes all liability to any person for any consequences, including but not limited to all losses, damages, costs, expenses and any other compensation, arising directly or indirectly from using this publication (in part or in whole) and any information or material contained in it.

Contents

| | | |
|-----|--|----|
| 1 | Introduction | 5 |
| 1.1 | Identification of specimen | 5 |
| 1.2 | Sponsor | 5 |
| 1.3 | Manufacturers | 5 |
| 1.4 | Test standards..... | 5 |
| 1.5 | Reference standard..... | 5 |
| 1.6 | Test number..... | 5 |
| 1.7 | Test date | 6 |
| 2 | Description of specimen | 6 |
| 2.1 | General..... | 6 |
| 2.2 | Orientation..... | 8 |
| 2.3 | Dimensions | 8 |
| 2.4 | Restraints | 9 |
| 2.5 | Conditioning..... | 9 |
| 2.6 | Selection, construction and installation of the specimen and the supporting construction | 9 |
| 3 | Documentation | 9 |
| 4 | Equipment..... | 9 |
| 4.1 | Furnace | 9 |
| 4.2 | Temperature | 10 |
| 4.3 | Measurement system | 10 |
| 5 | Ambient temperature: | 10 |
| 6 | Departure from standard:..... | 10 |
| 7 | Termination of the test: | 10 |
| 8 | Test results | 11 |
| 8.1 | Critical observations | 11 |
| 8.2 | Furnace temperature..... | 11 |
| 8.3 | Furnace severity..... | 11 |
| 8.4 | Specimen temperature | 11 |
| 8.5 | Performance | 12 |
| 9 | Fire-Resistance Level (FRL):..... | 13 |
| 10 | Field of direct application of test results: | 13 |
| 11 | Tested by: | 13 |
| | Appendices | 14 |
| | Appendix A – Measurement location | 14 |
| | Appendix B – Test photographs | 15 |
| | Appendix C – Test data charts..... | 19 |
| | Appendix D – Specimen drawings | 24 |
| | Appendix E – Certificate(s) of Test | 26 |
| | References..... | 29 |

Fire-resistance test on sealing systems protecting control joints in concrete walls

Sponsored Investigation No. FSP 1819

1 Introduction

1.1 Identification of specimen

The sponsor identified the test specimen as Sikaflex 400 Fire sealant protecting control joints in concrete walls.

1.2 Sponsor

Sika Australia Pty Ltd
55 Elizabeth Street
Wetherill Park NSW

1.3 Manufacturers

Sika Ltd
1-1 Nagatoro, Hiratsuka-shi
Kanagawa 254-0021
Japan

1.4 Test standards

Australian Standard 1530, Methods for fire tests on building materials, components and structures, Part 4 – 2014, Fire-resistance tests of elements of construction.

Section 10: Service penetrations and control joints.

1.5 Reference standard

Australian Standard 4072, Components for the protection of openings in fire-resistant separating elements, Part 1 - 2005, Service penetrations and control joints.

1.6 Test number

CSIRO Reference test number FS4652/4071.

1.7 Test date



The fire-resistance test was conducted on 7 February 2017.

2 Description of specimen



2.1 General

The specimen comprised three 1000-mm exposed length control joints formed in 150-mm thick concrete wall. The joints were protected with Sikaflex 400 Fire sealant.



Specimen 1 – 20-mm wide control joint protected by Sikaflex 400 Fire sealant applied from the fire exposed side

| SEPERATING ELEMENT | |
|---|--|
| 150-mm thick concrete wall, with an established FRL of -/240/240. | |
| SIZE OF OPENING | |
| 25-mm wide x 1000-mm exposed length. | |
| FIRE STOPPING SYSTEM | |
| Trade name | Sikaflex 400 Fire sealant |
| Manufacturer | Sika Australia Pty Ltd |
| Size | 20-mm wide x 10-mm deep x 1000-mm long |
| Description | one component moisture curing, elastic joint sealant |
| Installation | The 20-mm wide joint was protected with Sikaflex 400 Fire sealant installed from the exposed side of the wall. The sealant was applied to a depth of 10-mm controlled by a 30-mm x 20-mm polyurethane foam backing rod, and finished flush with the exposed face of the wall. |
| Photographs | <div style="display: flex; justify-content: space-around;"> <div style="text-align: center;">  <p>fire exposed face</p> </div> <div style="text-align: center;">  <p>unexposed face</p> </div> </div> |
| Drawings | Drawings numbered 1 and 2, both dated 21 December 2016, by Sika Australia Pty Ltd. |

Specimen 2 – 20-mm wide control joint protected by Sikaflex 400 Fire sealant applied from both sides

| SEPERATING ELEMENT | |
|---|--|
| 150-mm thick concrete wall, with an established FRL of -/240/240. | |
| SIZE OF OPENING | |
| 25-mm wide x 1000-mm exposed length. | |
| FIRE STOPPING SYSTEM | |
| Trade name | Sikaflex 400 Fire sealant |
| Manufacturer | Sika Australia Pty Ltd |
| Size | 20-mm wide x 10-mm deep x 1000-mm long |
| Description | one component moisture curing, elastic joint sealant |
| Installation | The 20-mm wide joint was protected with Sikaflex 400 Fire sealant installed from both sides of the wall. The sealant was applied to a depth of 10-mm controlled by a 30-mm x 20-mm polyurethane foam backing rod, and finished flush with both faces of the wall. |
| Photographs | <div style="display: flex; justify-content: space-around;"> <div style="text-align: center;">  <p>fire exposed face</p> </div> <div style="text-align: center;">  <p>unexposed face</p> </div> </div> |
| Drawings | Drawings numbered 1 and 2, both dated 21 December 2016, by Sika Australia Pty Ltd. |

Specimen 3 – 20-mm wide control joint protected by Sikaflex 400 Fire sealant applied from the non-fire side

| SEPERATING ELEMENT | |
|---|--|
| 150-mm thick concrete wall, with an established FRL of -/240/240. | |
| SIZE OF OPENING | |
| 25-mm wide x 1000-mm exposed length. | |
| FIRE STOPPING SYSTEM | |
| Trade name | Sikaflex 400 Fire sealant |
| Manufacturer | Sika Australia Pty Ltd |
| Size | 20-mm wide x 10-mm deep x 1000-mm long |
| Description | one component moisture curing, elastic joint sealant |
| Installation | The 20-mm wide joint was protected with Sikaflex 400 Fire sealant installed from the unexposed or non-fire side of the wall. The sealant was applied to a depth of 10-mm controlled by a 30-mm x 20-mm polyurethane foam backing rod, and finished flush with the unexposed face of the wall. |
| Photographs | <div style="display: flex; justify-content: space-around;"> <div style="text-align: center;">  <p>fire exposed face</p> </div> <div style="text-align: center;">  <p>unexposed face</p> </div> </div> |
| Drawings | Drawings numbered 1 and 2, both dated 21 December 2016, by Sika Australia Pty Ltd. |

2.2 Orientation

The control joints were tested in a vertical plane and exposed to fire from one side only.

2.3 Dimensions

The overall exposed length of the control joint specimens was 1000-mm, to suit the opening in the specimen containing frame.

2.4 Restraints

The concrete slab was restrained along all four sides.

2.5 Conditioning

The specimen installation was finalised on 17 January 2017 and the specimen was stored under laboratory conditions until the day of the test.

2.6 Selection, construction and installation of the specimen and the supporting construction

The construction was organised by the sponsor. CSIRO was not involved in the selection of the materials.

3 Documentation

The following documents were supplied or referenced by the sponsor as a complete description of the specimen and should be read in conjunction with this report:

- Drawings numbered 1 and 2, both dated 21 December 2016, by Sika Australia Pty Ltd.

Confidential information about the test specimen has been submitted and is retained at CSIRO Infrastructure Technologies.

4 Equipment

4.1 Furnace

The furnace had a nominal opening of 1000-mm x 1000-mm for attachment of vertical or horizontal specimens.

The furnace was lined with refractory bricks and materials with the thermal properties as specified in AS 1530.4-2014 and was heated by combustion of a mixture of natural gas and air.

4.2 Temperature

The temperature in the furnace chamber was measured by four type K, 3-mm diameter, and 310 stainless steel Mineral Insulated Metal Sheathed (MIMS) thermocouples. Each thermocouple was housed in high-nickel steel tubes opened at the exposed end.

The temperatures of the specimen were measured by glass-fibre insulated and sheathed K-type thermocouples with a wire diameter of 0.5-mm.

Locations of the thermocouples on the unexposed face of the specimen are described in Appendix A.

4.3 Measurement system

The primary measurement system comprised multiple-channel data loggers, scanning at one minute intervals during the test.

5 Ambient temperature

The temperature of the test area was 25°C at the commencement of the test.

6 Departure from standard

There were no departures from the requirements of AS 1530.4-2014.

7 Termination of the test

The test was terminated at 241 minutes by the agreement with the sponsor.

8 Test results

8.1 Critical observations

The following observations were made during the fire-resistance test:

- 5 minutes - Moisture is forming on the unexposed face of the wall.
- 16 minutes - Smoke is emitted from inside the joint of Specimen 1.
- 20 minutes - Insulation failure of Specimen 1 – maximum temperature rise of 180 deg C is exceeded on the unexposed face of the sealant.
- 21 minutes - Glow is visible inside the joint of Specimen 1.
- 120 minutes - No apparent change to the specimens.
- 160 minutes - Slight charring is evident along the edges of the sealant in joint of Specimen 3.
- 161 minutes - Insulation failure of Specimen 3 – maximum temperature rise of 180 deg C is exceeded on the unexposed face of the sealant.
- 210 minutes - The sealant in joint of Specimen 3 has discoloured. Charring is evident along the edges of the sealant in joint of Specimen 2.
- 223 minutes - Insulation failure of Specimen 2 – maximum temperature rise of 180 deg C is exceeded on the unexposed face of the sealant.
- 241 minutes - Test terminated.

8.2 Furnace temperature

Figure 1 shows the standard curves of temperature versus time for heating the furnace chamber and the actual curves of average and maximum temperature versus time recorded during the heating period.

8.3 Furnace severity

Figure 2 shows the curve of furnace severity versus time during the heating period.

8.4 Specimen temperature

Figure 3 shows curves of temperature versus time recorded on the unexposed face of Specimen 1.

Figure 4 shows curves of temperature versus time recorded on the unexposed face of Specimen 2.

Figure 5 shows curves of temperature versus time recorded on the unexposed face of Specimen 3.

8.5 Performance

Performance observed in respect of the following AS 1530.4-2014 criteria:

| | SPECIMEN 1 | |
|---------------------|------------|---------------------------|
| Structural adequacy | - | not applicable |
| Integrity | - | no failure at 241 minutes |
| Insulation | - | 20 minutes |
| | SPECIMEN 2 | |
| Structural adequacy | - | not applicable |
| Integrity | - | no failure at 241 minutes |
| Insulation | - | 223 minutes |
| | SPECIMEN 3 | |
| Structural adequacy | - | not applicable |
| Integrity | - | no failure at 241 minutes |
| Insulation | - | 161 minutes |

This report details methods of construction, the test conditions and the results obtained when specific element of construction described herein was tested following the procedure outlined in this standard. Any significant variation with respect to size, constructional details, loads, stresses, edge or end conditions, other than those allowed under the field of direct application in the relevant test method, is not covered by this report.

Because of the nature of fire resistance testing and the consequent difficulty in quantifying the uncertainty of measurement of fire resistance, it is not possible to provide a stated degree of accuracy of the result.

9 Fire-Resistance Level (FRL)

For the purpose of building regulations in Australia, the FRLs of the test specimens were as follows:

Specimen 1: -/240/0,

Specimen 2: -/240/180; and

Specimen 3: -/240/120

The fire-resistance levels of the specimen are applicable when the system is exposed to fire from the either direction.

For the purposes of AS 1530.4-2014 the results of these fire tests may be used to directly assess fire hazard, but it should be noted that a single test method will not provide a full assessment of fire hazard under all fire conditions.

10 Field of direct application of test results

The results of the fire test contained in this test report are directly applicable, without reference to the testing authority, to similar constructions where one or more changes listed in Clause 10.12 of AS1530.4-2014, have been made provided no individual component is removed or reduced.

11 Tested by



Chris Wojcik
Testing Officer

Appendices


Appendix A – Measurement location

| Measurement Location | | |
|----------------------|---|-----------------|
| Group location | T/C Position | T/C designation |
| Specimen | | |
| | | |
| Specimen 1 | On the back of backing rod – $\frac{3}{4}$ height | S1 |
| | On the back of backing rod – $\frac{1}{2}$ height | S2 |
| | On the back of backing rod – $\frac{1}{4}$ height | S3 |
| | 25-mm from the joint - $\frac{3}{4}$ height | S4 |
| | 25-mm from the joint - $\frac{1}{2}$ height | S5 |
| | 25-mm from the joint - $\frac{1}{4}$ height | S6 |
| Specimen 2 | On the sealant – $\frac{3}{4}$ height | S7 |
| | On the sealant – $\frac{1}{2}$ height | S8 |
| | On the sealant – $\frac{1}{4}$ height | S9 |
| | 25-mm from the joint - $\frac{3}{4}$ height | S10 |
| | 25-mm from the joint - $\frac{1}{2}$ height | S11 |
| | 25-mm from the joint - $\frac{1}{4}$ height | S12 |
| Specimen 3 | On the sealant – $\frac{3}{4}$ height | S13 |
| | On the sealant – $\frac{1}{2}$ height | S14 |
| | On the sealant – $\frac{1}{4}$ height | S15 |
| | 25-mm from the joint - $\frac{3}{4}$ height | S16 |
| | 25-mm from the joint - $\frac{1}{2}$ height | S17 |
| | 25-mm from the joint - $\frac{1}{4}$ height | S18 |
| Rover | | S19 |
| Ambient | | S20 |


Appendix B – Test photographs




PHOTOGRAPH 1 – EXPOSED FACE OF THE SPECIMENS PRIOR TO TEST




PHOTOGRAPH 2 – UNEXPOSED FACE OF THE SPECIMENS PRIOR TO TESTING




PHOTOGRAPH 3 – SPECIMENS AT 30 MINUTES INTO THE TEST



PHOTOGRAPH 4 – SPECIMENS AT 60 MINUTES INTO THE TEST




PHOTOGRAPH 5 – SPECIMENS AT 120 MINUTES INTO THE TEST



PHOTOGRAPH 6 – SPECIMENS AT 180 MINUTES INTO THE TEST



PHOTOGRAPH 7 – SPECIMENS AT THE CONCLUSION OF TESTING



PHOTOGRAPH 8 – EXPOSED FACE OF THE SPECIMEN AFTER THE CONCLUSION OF TESTING

Appendix C – Test data charts




FIGURE 1 – FURNACE TEMPERATURE




FIGURE 2 – FURNACE SEVERITY




FIGURE 3 – SPECIMEN TEMPERATURE – UNEXPOSED FACE OF CONTROL JOINT 1




FIGURE 4 – SPECIMEN TEMPERATURE – UNEXPOSED FACE OF CONTROL JOINT 2





FIGURE 5 – SPECIMEN TEMPERATURE – UNEXPOSED FACE OF CONTROL JOINT 3

Appendix D – Specimen drawings

WALL ASSEMBLY- AS1530.4 COMPLIANCE TEST FOR SIKA AUSTRALIA PTY LTD



NO OF JOINTS – 3

JOINT WIDTH – 20mm

THICKNESS OF CONCRETE – 150mm

DISTANCE BETWEEN JOINTS > 200mm

JOINT 1 SEALANT –

SIKAFLEX 400 FIRE - SEALED ON THE FIRE SIDE.

WIDTH 20mm; DEPTH 10mm;

WITH PU FOAM BACKING ROD (30X20mm)

JOINT 2 SEALANT –

SIKAFLEX 400 FIRE - SEALED ON BOTH SIDES.

WIDTH 20mm; DEPTH 10mm;

WITH PU FOAM BACKING ROD (30X20mm)

JOINT 3 SEALANT –

SIKAFLEX 400 FIRE - SEALED ON THE NON-FIRE SIDE.

WIDTH 20mm; DEPTH 10mm;


WITH PU FOAM BACKING ROD (30X20mm)

DRAWING 1


PREPARED BY: Rohanthi De Silva
DATE: 21/12/2016

DRAWING NUMBERED 1, DATED 21 DECEMBER 2016, BY SIKA AUSTRALIA PTY LTD

FIRE SIDE



NON-FIRE SIDE



DRAWING 2
PREPARED BY: Rohanthi De Silva
DATE: 21/12/2016

DRAWING NUMBERED 2, DATED 21 DECEMBER 2016, BY SIKA AUSTRALIA PTY LTD

Appendix E – Certificate(s) of Test

| | | |
|---|---|---|
| INFRASTRUCTURE TECHNOLOGIES www.csiro.au | |  |
| 14 Julius Avenue, North Ryde NSW 2113 PO Box 310, North Ryde NSW 1670, Australia T (02) 9490 5444 • ABN 41 687 119 230 | | |
| <h3>Certificate of Test</h3> | | No. 2937 |
| <small>“Copyright CSIRO 2017 ©” Copying or alteration of this report without written authorisation from CSIRO is forbidden.</small> | | |
| This is to certify that the element of construction described below was tested by CSIRO Infrastructure Technologies in accordance with Australian Standard 1530, Methods for fire tests on building materials, components and structures, Part 4-2014 Fire-resistance tests of elements of construction, on behalf of: | | |
| Sika Australia Pty Ltd 55 Elizabeth Street Wetherill Park NSW | | |
| A full description of the test specimen and the complete test results are detailed in the Division's Sponsored Investigation report numbered FSP 1819. | | |
| Product Name: | Specimen 1 - Sikaflex 400 Fire sealant applied from exposed side protecting a 20-mm wide control joint in a concrete wall | |
| Description: | The sponsor identified the test specimen as Sikaflex 400 Fire sealant protecting control joints in concrete walls. The separating element was a 150-mm thick concrete wall, with an established FRL of -/240/240. The size of the opening was 25-mm wide x 1000-mm exposed length. The fire stopping system measuring 20-mm wide x 10-mm deep x 1000-mm long is described as a one component moisture curing, elastic joint sealant. The 20-mm wide joint was protected with Sikaflex 400 Fire sealant installed from the exposed side of the wall. The sealant was applied to a depth of 10-mm controlled by a 30-mm x 20-mm polyurethane foam backing rod, and finished flush with the exposed face of the wall. Refer to Drawings numbered 1 and 2, both dated 21 December 2016, by Sika Australia Pty Ltd for a complete description of the specimen. | |
| | Structural Adequacy | not applicable |
| | Integrity | No failure at 241 minutes |
| | Insulation | 20 minutes |
| and therefore for the purpose of Building Regulations in Australia, achieved a fire-resistance level (FRL) of -/240/0. The fire-resistance levels (FRL) of the specimen are applicable when the system is exposed to fire from the either direction. This certificate is provided for general information only and does not comply with regulatory requirements for evidence of compliance. | | |
| Testing Officer: | Chris Wojcik | Date of Test: 7 February 2017 |
| Issued on the 27 th day of March 2017 without alterations or additions. | | |
|  | | |
| Brett Roddy Manager, Fire Testing and Assessments | | |
|  | This document is issued in accordance with NATA's accreditation requirements. Accreditation No. 165 – Corporate Site No. 3625 Accredited for compliance with ISO/IEC 17025 - Testing | |

CERTIFICATE OF TEST NO. 2937



Certificate of Test

No. 2938

“Copyright CSIRO 2017 ©”
Copying or alteration of this report
without written authorisation from CSIRO is forbidden.

This is to certify that the element of construction described below was tested by CSIRO Infrastructure Technologies in accordance with Australian Standard 1530, Methods for fire tests on building materials, components and structures, Part 4-2014 Fire-resistance tests of elements of construction, on behalf of:

Sika Australia Pty Ltd
55 Elizabeth Street
Wetherill Park NSW

A full description of the test specimen and the complete test results are detailed in the Division's Sponsored Investigation report numbered FSP 1819.

Product Name: Specimen 2 - Sikaflex 400 Fire sealant applied from both sides protecting a 20-mm wide control joint in a concrete wall

Description: The sponsor identified the test specimen as Sikaflex 400 Fire sealant protecting control joints in concrete walls. The separating element was a 150-mm thick concrete wall, with an established FRL of -/240/240. The size of the opening was 25-mm wide x 1000-mm exposed length. The fire stopping system measuring 20-mm wide x 10-mm deep x 1000-mm long is described as a one component moisture curing, elastic joint sealant. The 20-mm wide joint was protected with Sikaflex 400 Fire sealant installed from both sides of the wall. The sealant was applied to a depth of 10-mm controlled by a 30-mm x 20-mm polyurethane foam backing rod, and finished flush with both faces of the wall. Refer to Drawings numbered 1 and 2, both dated 21 December 2016, by Sika Australia Pty Ltd for a complete description of the specimen.

| | |
|---------------------|---------------------------|
| Structural Adequacy | not applicable |
| Integrity | No failure at 241 minutes |
| Insulation | 223 minutes |

and therefore for the purpose of Building Regulations in Australia, achieved a fire-resistance level (FRL) of -/240/180. The fire-resistance levels (FRL) of the specimen are applicable when the system is exposed to fire from the either direction. This certificate is provided for general information only and does not comply with regulatory requirements for evidence of compliance.

Testing Officer: Chris Wojcik **Date of Test:** 7 February 2017

Issued on the 27th day of March 2017 without alterations or additions.

Brett Roddy
Manager, Fire Testing and Assessments



This document is issued in accordance with NATA's accreditation requirements.
Accreditation No. 165 – Corporate Site No. 3625
Accredited for compliance with ISO/IEC 17025 - Testing

CERTIFICATE OF TEST NO. 2938



Certificate of Test

No. 2939

“Copyright CSIRO 2017 ©”
Copying or alteration of this report
without written authorisation from CSIRO is forbidden.

This is to certify that the element of construction described below was tested by CSIRO Infrastructure Technologies in accordance with Australian Standard 1530, Methods for fire tests on building materials, components and structures, Part 4-2014 Fire-resistance tests of elements of construction, on behalf of:

Sika Australia Pty Ltd
55 Elizabeth Street
Wetherill Park NSW

A full description of the test specimen and the complete test results are detailed in the Division's Sponsored Investigation report numbered FSP 1819.

Product Name: Specimen 3 - Sikaflex 400 Fire sealant applied from unexposed side protecting a 20-mm wide control joint in a concrete wall

Description: The sponsor identified the test specimen as Sikaflex 400 Fire sealant protecting control joints in concrete walls. The separating element was a 150-mm thick concrete wall, with an established FRL of -/240/240. The size of the opening was 25-mm wide x 1000-mm exposed length. The fire stopping system measuring 20-mm wide x 10-mm deep x 1000-mm long is described as a one component moisture curing, elastic joint sealant. The 20-mm wide joint was protected with Sikaflex 400 Fire sealant installed from the unexposed or non-fire side of the wall. The sealant was applied to a depth of 10-mm controlled by a 30-mm x 20-mm polyurethane foam backing rod, and finished flush with the unexposed face of the wall. Refer to Drawings numbered 1 and 2, both dated 21 December 2016, by Sika Australia Pty Ltd for a complete description of the specimen.

| | |
|---------------------|---------------------------|
| Structural Adequacy | not applicable |
| Integrity | No failure at 241 minutes |
| Insulation | 161 minutes |

and therefore for the purpose of Building Regulations in Australia, achieved a fire-resistance level (FRL) of -/240/120. The fire-resistance levels (FRL) of the specimen are applicable when the system is exposed to fire from the either direction. This certificate is provided for general information only and does not comply with regulatory requirements for evidence of compliance.

Testing Officer: Chris Wojcik **Date of Test:** 7 February 2017

Issued on the 27th day of March 2017 without alterations or additions.


Brett Roddy
Manager, Fire Testing and Assessments



This document is issued in accordance with NATA's accreditation requirements.
Accreditation No. 165 – Corporate Site No. 3625
Accredited for compliance with ISO/IEC 17025 - Testing

CERTIFICATE OF TEST NO. 2939

References

The following informative documents are referred to in this Report:

- AS 1530.4-2014 Methods for fire tests on building materials, components and structures - Part 4: Fire-resistance tests of elements of building construction.
- AS 4072.1-2005 Components for the protection of openings in fire-resistant separating elements, Part 1: Service penetrations and control joints.

END OF REPORT

CONTACT US

t 1300 363 400
+61 3 9545 2176
e enquiries@csiro.au
w www.csiro.au

YOUR CSIRO

Australia is founding its future on science and innovation. Its national science agency, CSIRO, is a powerhouse of ideas, technologies and skills for building prosperity, growth, health and sustainability. It serves governments, industries, business and communities across the nation.

FOR FURTHER INFORMATION

Infrastructure Technologies

Chris Wojcik
Manager Fire Resistance Testing
t +61 2 9490 5508
e chris.wojcik@csiro.au
w www.csiro.au/Organisation-Structure/Divisions/CMSE/Infrastructure-Technologies/Fire-safety.aspx

Infrastructure Technologies

Brett Roddy
Team Leader, Fire Testing and Assessments
t +61 2 9490 5449
e brett.rodny@csiro.au
w www.csiro.au/Organisation-Structure/Divisions/CMSE/Infrastructure-Technologies/Fire-safety.aspx