


BGC Fibre Cement

Cavity Batten Note:

Refer to cavity batten layout for batten sizes, types, spacing's & fixings

Cladding fixing note:

Refer to cladding fixing layout for all fixing types & spacing's



Aluminium window joinery.

Durabarrier™ or building underlay and flexible flashing tape. Flexible flashing tape to be continuous along sill, 100mm min. up each jamb and 50mm onto face of building underlay.

8mm Min cover to Stratum™ by aluminium window joinery.

Compressible foam seal tightly finished against cladding or Bostik Seal 'N' Flex sealant. Sill support bar.

Stratum[™] adhered to batten with cont. 6mm bead of Bostik Seal 'N' Flex FC (not shown for clarity).

BGC Stratum TM with all cut sheet edges sealed before fixing. Durabarrier™ or approved breather type building underlay.

H3.1 treated SG8 timber cavity batten

Note. Where Durabarrier™ is used flashing tape must be applied to the entire opening

DETAIL

BGC Stratum™ and Stratum™ Duo PROFILE

> 1:5 @ A4 SCALE

Jan 2014

DATE

Window Sill Detail DETAIL NO. ST-17 **Cavity Construction**