

VOC Content Test Certificate

Wednesday 4th August 2010

Manufacturer: PolyFlor Pty Ltd (59-65 Wedgewood Rd, Hallam, VIC, 3803)

Sample Description: Kiesel Okatmos Star 150 Pressure Sensitive / Releasable Adhesive

Date Tested: July 2010 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

Specification	
Green Building Council of Australia Green Star Office Design V2 IEQ-13	Kiesel Okatmos Star 150 Adhesive
Sub Floor Adhesive 50 grams per Litre as VOC content material	49 grams per Litre as VOC content material
Specification	
Green Building Council of Australia Green Star Office Design V3 IEQ-13	Kiesel Okatmos Star 150 Adhesive
Sub Floor Adhesive 50 grams per Litre as VOC content material	49 grams per Litre as VOC content material



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

F1007-16