





Accredited for compliance with ISO/IEC 17025 -Testing

NATA is a signatory to the ILAC Mutual Recognition Arrangement for the mutual recognition of the equivalence of testing, medical testing, calibration and inspection reports

## **OIL-WET INCLINING PLATFORM SLIP RESISTANCE TEST**

GT Emboss-001 vinyl plank

Prepared for: Armstrong Flooring

Jun Phang

29-39 Mills Road

**BRAESIDE VIC 3195** 

Sample Description: GT Emboss-001 vinyl plank

No. of Specimens &

Size Supplied:

3 off, 185x1500 mm, (Sampling Conducted by Client)

Surface Structure: Smooth

**Specimen Preparation:** Washed with water and pH neutral detergent, rinsed then dried.

Specimen Configuration: Unfixed

**Test Direction:** Test conducted parallel with embossed finish.

Joint Type & Width: N/A
Air Temperature: 21°C

**Test Standard:** AS 4586:2013 Slip resistance classification of new pedestrian surface

materials, Appendix D - Oil Wet Inclining Platform Test

**Test Shoe:** Leipzig V73-SP

Test Location: ATTAR 44-48 Rocco Drive, Scoresby, VIC, 3179

Test Date: 15 March 2024

Test Personnel: Marcus Bosworth and Louie Karkatzoulis

| Displacement Space                                          | Not tested |  |
|-------------------------------------------------------------|------------|--|
| (rounded to the nearest 0.5cm³/dm²):                        | Not lested |  |
| Displacement Space Assessment Group                         | Not tested |  |
| (Appendix E, AS 4586 - 2013):                               | Not lested |  |
| Corrected mean overall acceptance angle (α <sub>ave</sub> ) | 11°        |  |
| (rounded down to the nearest degree):                       | "          |  |
| Classification:                                             | R10        |  |

These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service conditions, including maintenance procedures and wear on their slip resistance be checked.

Prepared By:

Marcus Bosworth

Compliance and Testing Technician

Reviewed By:

Marcus Braché

Senior Engineering Technician

Approved Signatory





Figure 1: GT Emboss-001 vinyl plank
Arrow indicates direction of testing



## <u>CLASSIFICATION CRITERIA – AS 4586 - 2013</u> <u>Oil Wet Inclining Platform Test – Appendix D</u>

## Compliance

TABLE 5: CLASSIFICATION OF PEDESTRIANSURFACE MATERIALS ACCORDING TO THE OIL-WET INCLINING PLATFORM TEST

| Classification    | Angle, degrees |
|-------------------|----------------|
| No Classification | <6             |
| R9                | ≥6 <10         |
| R10               | ≥10 <19        |
| R11               | ≥19 <27        |
| R12               | ≥27 <35        |
| R13               | ≥35            |