

# VOC Content Test Certificate

Wednesday August 22<sup>nd</sup>, 2012

Manufacturer: Polyflor Australia (59-65 Wedgewood Rd, Hallam VIC 3803)

Sample Description: BF 850

Date Tested: August 2012 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 303-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168

Test Data:

<b>Specification</b>  <b>Green Building Council of Australia</b> <b>Green Star Office Design V3 IEQ-13</b>	<b>BF 850</b>
Architectural sealant  250 grams per Litre as VOC content per material	<b>11 grams per Litre as VOC content per material</b>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Anne Saletti  
BNanotech/BSc(Hons)  
Consultant

CV120811