

ANALYSIS CERTIFICATE

2 September, 2022

OUR REF:	108009A
TO:	Ardex NZ Ltd
ATTN:	Steven Irvine

SAMPLE OF:	Ardex A38	SAMPLE TYPE:	As received
SAMPLE TYPE:	Rapid Set Screed Cement	DATE RECEIVED:	31/08/2022
SAMPLE DATE:	-	DATE TESTED:	01-02/09/2022
		ORDER NO:	VOC testing

	Result	Method
Total Non-Volatile Content, %w/w	99.5	<i>Oven-drying @ 110°C (60mins)</i>
Total Water Content, %w/w	-	<i>Karl Fischer titration</i>
Density, g/mL	1.34	<i>Gravimetry</i>
Exempt Compounds	None specified	

	Result	Method
Total Volatile Organic Compounds, g/L	<7	<i>SCAQMD METHOD 304-91</i>



 Analyst



 Authorised by

This report relates only to the sample provided

This Report Shall Not Be Reproduced Except In Full
MEMBER OF THE NEW ZEALAND ASSOCIATION OF CONSULTING LABORATORIES